

VOC Content Test Certificate

Thursday, March 07, 2013

Manufacturer: Holdfast Adhesives Australia Pty Ltd
90 – 92 Bay Street,
Botany, NSW, 2019

Sample Description: Adhesive 104

Date Tested: January 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in
Various Materials as referenced by South Coast Air Quality Management Division
(SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Adhesive 104
Carpet Adhesive 50 grams per Litre	24 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project F0801-02