

# VOC Content Test Certificate

Friday May 16<sup>th</sup>, 2008

Manufacturer: RLA Polymers Pty Ltd  
 215 Colchester Road  
 Kilsyth Victoria 3137

Sample Description: GS444 adhesive

Date Tested: May 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>GS444 Adhesive</b>
Indoor carpet adhesive 50 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>GS444 Adhesive</b>
Indoor carpet adhesive 50 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

F0805-36